

Monthly Summary of EPA Monitoring Data with Limits



Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the written requirements issued by the NSW Environment Protection Authority. To the best of Kimbriki Environmental Enterprises' knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior written consent from Kimbriki Environmental Enterprises. For more details on publication of pollution monitoring data please refer to the NSW EPA Website, <http://www.epa.nsw.gov.au/index.htm>

Monitoring Period	Jan-18						
Date Published	16 February 2018						
EPA Licence No.	13091						
EPA Licence Hyperlink	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=32504&SYSUID=1&LICID=13091						
Licensee Name	KIMBRIKI ENVIRONMENTAL ENTERPRISES PTY LIMITED						
Licensee Address	PO BOX 196, Terrey Hills, NSW 2084						
Monitoring Location (EPA Point 1)	Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 1)						
Explanatory Notes	No surface water discharge occurred from this monitoring point during the month.						
Monitoring Location (EPA Point 2)	Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 2)						
Explanatory Notes	No surface water discharge occurred from this monitoring point during the month.						
Monitoring Location (EPA Point 3)	Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 3)						
Explanatory Notes	No surface water discharge occurred from this monitoring point during the month.						
Monitoring Location (EPA Point 21)	Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 21)						
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Max. value	100 percentile limit	Exceed-ance (yes/no)
Biochemical oxygen demand	mg/L (Note 1)	Special Frequency 1 (Note 2)	1	<5	<5	20	no
Nitrogen (ammonia)	mg/L (Note 1)	Daily during any discharge	1	0.03	0.03	1	no
pH	pH	Daily during any discharge	1	7.70	7.70	6.5-8.5	no
Total suspended solids	mg/L (Note 1)	Daily during any discharge	1	<5	<5	50	no
Explanatory Notes	(Note 1) mg/L (milligrams per litre) (Note 2) Special Frequency 1 - Quarterly and on the first day of discharge						
Monitoring Location (EPA Point 22)	Enclosed Ground Level Flare in the North-Eastern corner of the Premises. Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 22)						
Parameter	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Max. value	Lower Limit (Note 2)	Exceed-ance (yes/no)
Temperature	°C (Note 1)	Continuous	Continuous	792.1	817.7	760	no
Explanatory Notes	(Note 1) °C (degrees Celsius) (Note 2) The parameter value must be greater than the Lower Limit specified						

Monthly Summary of EPA Monitoring Data - No Limit



Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the written requirements issued by the NSW Environment Protection Authority. To the best of Kimbriki Environmental Enterprises' knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior written consent from Kimbriki Environmental Enterprises. For more details on publication of pollution monitoring data please refer to the NSW EPA Website, <http://www.epa.nsw.gov.au/index.htm>

Monitoring Period	Jan-18						
Date Published	16 February 2018						
EPA Licence No.	13091						
EPA Licence Hyperlink	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=32504&SYSUID=1&LICID=13091						
Licensee Name	KIMBRIKI ENVIRONMENTAL ENTERPRISES PTY LIMITED						
Licensee Address	PO BOX 196, Terrey Hills, NSW 2084						
Monitoring Location (EPA Point 1)	<i>Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 1)</i>						
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Median value	Max. value
Explanatory Notes	No surface water discharge occurred from this monitoring point during the month.						
Monitoring Location (EPA Point 2)	<i>Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 2)</i>						
Explanatory Notes	No surface water discharge occurred from this monitoring point during the month.						
Monitoring Location (EPA Point 3)	<i>Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 3)</i>						
Explanatory Notes	No surface water discharge occurred from this monitoring point during the month.						
Monitoring Location (EPA Point 21)	<i>Please refer to the map, Kimbriki Monitoring Sites.pdf, for location (EPA 21)</i>						
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Median value	Max. value
Conductivity	µS/cm (Note 1)	Daily during any discharge	1	693	693	693	693
Explanatory Notes	(Note 1) µS/cm (microsiemens per centimetre)						
Monitoring Location (EPA Point 22)	<i>Enclosed Ground Level Flare in the North-Eastern corner of the Premises.</i>						
Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Min. value	Mean value	Median value	Max. value
Volumetric flowrate	m ³ /h (Note 1)	Continuous	Continuous	0 (Note 2)	342	390	403
Explanatory Notes	(Note 1) m ³ /h (cubic metres per hour) (Note 2) Zero value due to: 1. Flare was shutdown for 3.5 hours on 3rd January 2018 due to a power outage. Flare was restarted remotely. 2. LFG flows showing inconsistent flow readings between 3rd and 5th January due to the faulty flow meter. Cumulative flows have been assumed to be zero for this period. 3. Flare was shutdown for 3.5 hour on 5th January 2018 for scheduled maintenance. 4. Flare was shutdown for 1.0 hour on 11th January 2018 for flow meter calibration. 5. Flare was shutdown for 25.0 hours on the 30th January 2018 due to oxygen infiltration into gas system.						